



Tiffany J. Moutis
Superintendent

Fred Knaak
Facility Manager

Mansfield Township School District

www.mansfieldschool.com
200 Mansfield Road East
Columbus, New Jersey
Phone: 609-298-2037 Ext. 2310

Dear John Hydock Elementary School Community,

On August 11, 2016 the Mansfield Township School District posted test results for lead in drinking water at the John Hydock Elementary School.

Of the five locations that tested above the 15ppb action level four were from non-drinking water sources and one was from a kitchen pot filler that was no longer in use.

Testing indicated that the likely source of the high lead level was from the faucet itself and not the pipes leading to the faucets.

To eliminate the elevated lead level at those sources the Building and Grounds department permanently removed the kitchen pot filler faucet and replaced the four other faucets with new lead free faucets.

The four locations where the faucets have been replaced were re-tested along with the new water cooler that was installed in the main office after the first round of testing.

The "Lead Water Sample Analysis Summary" indicates that all five locations tested are below the 15ppb action level.

Lab No. 6109209	Location: Aides Rm, Sink Faucet	Results (ppb):4.60
Lab No. 6109210	Location: Rm CR16, Sink	Results (ppb):5.10
Lab No. 6109211	Location: Kitchen Dishwasher Pre-rinse	Results (ppb):2.00
Lab No. 6109212	Location: Nurse's Office, Sink Faucet	Results (ppb):5.10
Lab No. 6109213	Location: Main Office, Water Cooler	Results (ppb):2.00

If you have any questions or concerns about the testing results contact Fred Knaak
Facilities Manager; fknaak@mansfieldschool.com